

Specification references

Conforms to:

CEN/TC 155 - Plastics piping systems and ducting systems

CEN/TC 164 - Water supply

DWI Advice Sheet 8

Small Surface Area Products (regulation 31(4)(b))

WIMES 8.02 6.10 :

2. The design of the sampling system shall ensure that representative samples of the dosed process fluid are continuously supplied to the monitoring equipment under all operating conditions.

Southeast Water GENIUS IS&S 28. 28.3 :

- 28.3 Suitable means to remove entrained air shall be provided where ever necessary, to ensure that the instrument operates with the required accuracy of measurement.